



- Type, batch or serial number or any other element allowing identification of the product

FTG18OM162,3,4,5 x from 1,5 to 35 mm²

Lot number: as indicated on cable, label and delivery note

- Declared performance

Unique identification code	Reaction to fire class	Dangerous substances
FTG18OM16	B2ca - s1a, d1, a1	None
Harmonized technical specification EN 50575:2016		

- System of assessment and verification of constancy of performance of the product

System AVCP 1+

- Notified product certification body

L.S. Fire Testing Institute Srl (n°2479)

performed the determination of the product-type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of FPC, the audit-testing of samples taken before placing the product on the market and publishes the certificate of constancy of performance

2479-CPR-E01329

- Intended use of the product

MULTI-CORE LSZH AND FIRE RESISTANT CABLE for energy with the aim of limiting the production and spread of fire and smoke

- Name of the manufacturer

SPECIALCAVI BALDASSARI SRL

Via G.Pieraccini 76 - 55012 Capannori(LU) - Italy

Tel. +39 0583 935741 Fax 0583 429474 Email: cpr@specialcavibaldassari.it**www.specialcavibaldassari.it/dop**

The performance of the product identified above is in conformity with the set of declared performances.
This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Capannori, 28/05/2024

Signed for and on behalf of the
manufacturer by
Marco Baldassari
Chief Executive Officer